

SUPPLEMENTAL / BID BULLETIN NO. 003

TITLE : SUPPLY , DELIVERY, INSTALLATION, AND CONFIGURATION OF SERVER WITH UPS AND NETWORK-ATTACHED STORAGE

ITB NO. : DSWD4B-2024-026

DATE : 12 AUGUST 2024

This Supplemental/Bid Bulletin is issued to all prospective bidders announcing the following:

PARTICULARS	CLARIFICATIONS/AMENDMENTS
Technical Specifications: SERVER Processor : Intel Xeon ≥ 2.2GHz 18-core	Technical Specifications: SERVER Processor : Intel Xeon ≥ 2.2GHz 18-core It should be: Processor : Intel Xeon ≥ 2.2GHz Quadcore
SERVER RAID : C4 Raid 5 for 3 or more HDDs or SSDs	SERVER RAID : C4 Raid 5 for 3 or more HDDs or SSDs It should be: RAID : Raid 5 for 3 or more HDDs or SSDs
Warranty and After-Sales Support. Does the " Warranty Period: 3 Year Parts / 3 Year Years Labor / 3 Years Onsite Support ", refer to all the items (Server, NAS and Data Cabinet)?	<ul style="list-style-type: none"> The 3-year parts and labor warranty shall cover the SERVER, UPS, and NAS. The UPS Battery shall only cover a two-year warranty The Data Cabinet is covered for one year.
To give us an overview of the infrastructure , may we know what is the purpose of the servers, NAS? What are the applications to be installed?	<ul style="list-style-type: none"> The NAS will be used for multipurpose tasks and various backup processes. We are specifically looking for a Synology NAS
What is the UPS required backup time and what is the specific percentage load? Who will provide the electrical tapping point and wirings? If the bidder, please specify the distance of 10KVA UPS to the electrical tapping point.	<ul style="list-style-type: none"> We've designed the UPS specifications to be more generic, allowing for broader compatibility with various systems. However, it is capable of supporting up to 10KVA. The winning bidder will provide the electrical tapping point and wirings at approximately 6-10 meters.

This Bid Bulletin shall form part of the bidding documents.

Please be guided accordingly.


KENNETH M. MONTENEGRO
 Chairperson
 Bids and Awards Committee

Please accomplish the portion below and email at procurement.fomimaropa@dswd.gov.ph.

Received from DSWD Field Office MIMAROPA, **Supplemental/Bid Bulletin No.3** for the **Supply , Delivery, Installation, and Configuration of Server with UPS and Network Attached Storage with Project ID No: DSWD4B-2024-026**

RECEIVED BY : _____ DATE: _____
(SIGNATURE OVER PRINTED NAME)

DESIGNATION : _____

COMPANY : _____